

Addendum #03



CLARK NEXSEN
4525 Main Street, Suite 1400
Virginia Beach, VA 23462
P: 757.455.5800
F: 757.455.5638

Project: Hofheimer Hall Second Floor Renovations
For Gynecology
Eastern Virginia Medical School

Issue Date: April 30, 2024

Project # CN# 10376; EVMS RFP# 24-EVMS-01-NWD

This addendum is issued pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Request for Proposals (RFP), Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contract Agreement.

This addendum addresses the following Bidder questions:

III-001: Pre-Proposal Question 11 – APC1 shows The Calla #2822 ceiling tile which is compatible with 15/16” grid. The grid specified, Interlude XL, is 9/16” grid. Please advise.

Response: In the Finish Legend on sheet IN601, replace APC1 with Calla #2824 ceiling tile.

Note: A signed acknowledgement of this addendum must be received at the location indicated on the Pricing Schedule attached to your proposal. Signature on this addendum does not substitute for your signature on the original proposal document. The original proposal must be signed. Faxed or e-mailed addenda will not be accepted.

END OF ADDENDUM NO. 03